

ADDENDUM NO. 1 BID OPPORTUNITY NO. 105-2004

ROOF REPLACEMENT AT BRONX C.C. – 131 CHELSEA PLACE

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: April 13, 2004 BY: Coleen Groening /clg TELEPHONE NO. (204) 986-2491

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid Submission non-responsive.

PART B - BIDDING PROCEDURES

Revise: B2.1 Submission Deadline to read:

B2.1 The Submission Deadline is 12:00 noon Winnipeg time, April 21, 2004.

PART E - SPECIFICATIONS

Add: .16 to Materials (page 3 of 8)

.16 <u>METAL SIDING</u>

.16 This shall be 24 gauge Vicwest CL815R or approved equal. Color is to be Stelco 8000 series black.

Delete: .07 of Description of Work (page 6 of 8)

Add: .27 to Description of Work (page 8 of 8)

.27 The existing wood siding band is to be removed and the new metal siding band installed. The new siding is to extend to the top of the parapets and to the same bottom elevation as the existing wood band. The top of the siding is to be secured to the parapet. The bottom and middle is to be secured to a new 3/4" deep 18 guage galvanized sheet metal hat bars of which are to be securely fastened to the existing concrete block walls. Secure the hat bars with #10 Tapcon screws spaced to more than 16" on centre staggering the screws from the top leg to the bottom leg. Install a matching color and thickness drip flashing along the bottom of the siding to ensure that the gap from the wall to the front face of the siding is closed off. Secure the new siding in place with matching color #10 hex head screws with neoprene washers