



FOR CONTINUATION, REFER TO DRAWING E2.4

PART MAIN FLOOR PLAN - PART C LIGHTING
SCALE 1/100

- NOTES
1. WORKROOM TO BE C/W CEILING MOUNTED DUAL-TEC SENSOR OCCUPANCY ON-OFF CONTROL OF LIGHTS (L474).
 2. LIGHTING LEVEL SENSOR AND OCCUPANCY SENSOR MOUNTED ON CEILING. PROGRAMMED TO TURN OFF ADJACENT FLUORESCENT LIGHTS.
 3. VALANCE LIGHTING.

Friesen Tokar Architects
200 - 2033 Portage Avenue
Winnipeg, Canada R3J 0K6
Tel. 204.885.9223
Fax. 204.831.7235

DATE	AA / RC
DATE	CB
DATE	APRIL 2004
PROJECT NO.	91716
REVISIONS	
1.	ISSUED FOR 50% REVIEW FEBRUARY 6, 2004
2.	ISSUED FOR 75% REVIEW MARCH 5, 2004
3.	ISSUED FOR PRETENDER REVIEW APRIL, 2004
4.	ISSUED FOR TENDER MAY 14, 2004

RI-ADDENDUM 2: GENERAL REVISION

SMS ENGINEERING
SMS Engineering Ltd., Consulting Engineers
778 Robinson Street Winnipeg, MB Canada R3B 0B6
Telephone 204.783.0889 Fax 204.782.2163
smsengineering.com

02-018-01

ORIGINAL CONTRACT DRAWING
ISSUED AND SEALED BY
ANDY LOHSE, P.E.N.G.
MAY 13, 2004

APEM
Certificate of Authorization
SMS Engineering Ltd.
No. 906 Expiry April 30, 2006

Drawings and specifications, as instruments of service are the property of the architect. No reproduction may be made without the permission of the architect and where made, must bear the name, address and telephone number of the architect.
The contractor shall verify dimensions and data noted herein with conditions on the site and be held responsible for reporting any discrepancies to the architect for adjustment.
This drawing shall not be used for building purposes until counter-signed by:

THE CITY OF WINNIPEG

OFFICE ADDITION AND RENOVATION
1155 PACIFIC AVENUE
WINNIPEG, MANITOBA

FRIESEN TOKAR ARCHITECTS

MAIN FLOOR PLAN
PART A - LIGHTING

E2.3R1