



Priesen Tokar Architects  
 200 - 2033 Portage Avenue  
 Winnipeg, Canada R3J 0K6  
 Tel. 204.885.9223  
 Fax. 204.831.7235

DRAWN BY: AA/RC  
 CHECKED BY: CB  
 DATE: MAY 2004  
 PROJECT NO.: 01716  
 TITLE: NTS

REVISIONS:  
 1. ISSUED FOR 50% REVIEW  
 FEBRUARY 6, 2004  
 2. ISSUED FOR 75% REVIEW  
 MARCH 5, 2004  
 3. ISSUED FOR PRETENDER REVIEW  
 APRIL, 2004  
 4. ISSUED FOR TENDER  
 MAY 14, 2004

RI-ADDENDUM 2: GENERAL  
 REVISION

**SMS ENGINEERING**  
 SMS Engineering Ltd. Consulting Engineers  
 778 Ross Street Winnipeg MB Canada R2N 3R6  
 Telephone: 204.775.0091 Fax: 204.772.2163  
 sms@smseng.com

02-018-01

ORIGINAL  
 CONTRACT DRAWING  
 BONDED AND SEALED BY  
 ANDY LOHSE, P.ENG.  
 MAY 13, 2004

**APEGM**  
 Certificate of Authorization  
 SMS Engineering Ltd.  
 No. 106 Expiry: April 30, 2005

Drawings and specifications, as  
 instruments of service are the  
 property of the architect. The  
 copyright in the same being  
 reserved to him. No reproduction  
 may be made without the  
 permission of the architect and  
 when made, must bear his name.  
 All rights to be retained by the  
 architect.  
 The contractor shall verify  
 dimensions and data noted herein  
 with conditions on the site and be  
 held responsible for reporting any  
 discrepancy to the architect for  
 adjustment.  
 This drawing shall not be used for  
 building purposes until  
 counterchecked by:

THE CITY OF  
 WINNIPEG

OFFICE ADDITION AND RENOVATION  
 1155 PACIFIC AVENUE  
 WINNIPEG, MANITOBA

**FRIESEN TOKAR ARCHITECTS**

MAIN FLOOR PLAN  
 PART C  
 POWER AND SYSTEMS  
**E2.8-R1**

- NOTES:
- 120V CIRCUIT FOR MOTORIZED PROJECTOR SCREEN. WIRE AND CONNECT AS REQUIRED.
  - 120V CIRCUIT FOR CEILING MOUNTED PROJECTOR. CEILING MOUNTED OUTLET BOX C/W FACEPLATE. 1/2" EMT DOWN TO WALL MOUNTED OUTLET BOX. PROVIDE FACEPLATES C/W 1/2" BUSHED HOLE AND PULLSTRING.
  - EXISTING PNEUMATIC AUTO-DOORS TO REMAIN.
  - EXISTING DOOR HAS A WOOD FRAME. WIRE TO ELECTRIC STRIKE FROM CRAMSPACE. PROVIDE WREMOULD FOR EXPOSED WIRING IF REQUIRED.
  - REMOVE EXISTING ALARM CONTACT ON THIS DOOR.
  - FIRE ALARM SYSTEM BELLS SHOWN RELOCATED ARE ACTUALLY NEW BELL-STROBES. EXTEND EXISTING CONDUIT AND REUSE CONDUIT WHERE SUITABLE. (TYPICAL FOR EXISTING BUILDING)

2018e2r1.dwg 6-17-04 3:18:40 pm CST