



ADDENDUM NO. 1 BID OPPORTUNITY NO. 153-2004

SUPPLY AND DELIVERY OF COLD WATER METERS

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: March 31, 2004
BY: Ken M. Stelmack, C.P.P., C.P.M., C.I.M. /kms
TELEPHONE NO. (204) 986-2293

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: 20040128

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid Submission non-responsive.

PART B – BIDDING PROCEDURES

Add: B9.1(i) to read:

- B9.1 (i) each meter supplied must have been manufactured by a company which has produced water meters of the size and type (bronze case positive displacement) offered for not less than ten (10) Years, and further each specific meter model(s) offered shall have been produced for not less than five (5) Years, minor modifications excepted.

PART D – SUPPLEMENTAL CONDITIONS

Add: D7.3 to read:

- D7.3 Notwithstanding GC:10.1, the warranty period shall be as specified in the Specification sections.

PART E – SPECIFICATIONS

Revise: E2.5(c) to read:

- E2.5 (c) should a meter not perform as specified, the Contractor shall replace it at no cost to the City of Winnipeg. A meter shall be determined **not to be performing** as specified if it fails to pass an accuracy test, conducted by the City of Winnipeg according to AWWA Standards. The warranty shall not apply to meters that have been damaged due to abnormal circumstances. It is intended that the warranty is applicable to meters that have been subjected to normal operating practices within the rated capacity of the meter.