



ADDENDUM NO. 1 BID OPPORTUNITY NO. 216-2004

REQUEST FOR QUALIFICATIONS FOR THE SUPPLY OF ULTRAVIOLET LIGHT DISINFECTION EQUIPMENT FOR THE NORTH END WATER POLLUTION CONTROL CENTRE DISINFECTION PROJECT

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: May 3, 2004
BY: Coleen Groening /clg
TELEPHONE NO. (204) 986-2491

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: 20040128

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 6 of Form A: Bid may render your Bid Submission non-responsive.

PART A – QUALIFICATION APPLICATION

Revise: Form B: Qualification Questionnaire

Part 1

Revise Question 3. as follows:

Revise text of sixth bullet to read

“Demonstrated that the reduction equivalent dosage to achieve the desired removal was in the range 15 to 50 mJ/cm²,”

Add the following note to Question 9, as follows:

Note: The term “reduction equivalent dose” refers to the method of performance testing the equipment. The UV dose at design flow, UVt and TSS conditions will be determined by recording the reduction of a challenge organism across the installed UV equipment, and then establishing the UV dose by use of a dose-response relationship derived from collimated beam tests.