



ADDENDUM NO. 1 to RFQ NO. 34-2004

METRO ROUTE 20 PUMPING STATION PIPING MODIFICATIONS

ISSUED: January 26, 2004
BUYER: Coleen Groening/clg
TELEPHONE NO. (204) 986-2491

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE RFQ**

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE REQUEST FOR QUOTATION AND
SHALL FORM A PART OF THE CONTRACT
DOCUMENTS**

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Request for Quotation, and be governed accordingly. Failure to acknowledge receipt of this Addendum on the cover page of the Bid Submission may render your Bid non-responsive.

Revise clauses 3.3.3 and 3.3.4 of the specifications to read:

3.3.3 All new station piping shall be ASTM A106 schedule 30 black seamless steel pipe

3.3.4 All flanges shall be 150 lb. to ANSI B16.5 and shall be raised face or full face to suit.

Revise Drawing LD-2990 as follows:

Change all references to Schedule 40 steel pipe to Schedule 30 steel pipe.

Revise note 4 to read “

4. ALL NEW STEEL PIPE TO BE ASTM A106 SCHEDULE 30 WITH FLANGED ENDS TO SUIT AND SHALL BE PRIMED AND PAINTED AS PER THE SPECIFICATIONS”