



NOTES: SEE DWG #1

UILT

MAY 9, 79	D	DETERMINED MK. 12	G.L.
APRIL 11, 79	C	REVISED CLASS OF PIPE	G.L.
DATE	NO	REVISION	BY

This drawing and all technical information appearing hereon are the property of CANRON INC. and must be kept in confidence by the recipient. The same may not be used or reproduced either in whole or in part without the express consent of CANRON INC. which reserves all rights of copyright.

CANRON MICROFILMED NOV -- 1981
INC. PIPE DIVISION

10813-2D-2D
THE CITY OF WINNIPEG
2743# SUCTION FROM RESERVOIR
DEACON BOOSTER PUMPING STATION

SCALE: _____ DATE: JANUARY 30, 1979

DRAWN	CHECKED	APPROVED	PROJECT	DWG.	REV.
G.L.	C.V.	<i>[Signature]</i>	46-5-8005	2	D

QTY	MK no	DIAMETER	DESCRIPTION	LENGTH	ENDS	REFERENCE
1	12	2743	108" SHORT PIPE WITH WATER STOP	1,103	3'-7 ¹¹ / ₁₆ "	P.C. & S. 46-5-8005-16
1	11	"	SHORT PIPE CL. 10	1,821	6'-0"	B. & S. 1.
18	STD.	"	STD. PIPE C-301 (E) CL. 10	6,096	20'-0"	B. & S.
3	STD.	2743	108" STD. PIPE C-301 (E) CL. 15	6,096	20'-0"	B. & S.

F1575 2 of 62