



ADDENDUM 1 BID OPPORTUNITY NO. 240-2005

WINNIPEG WATER TREATMENT PROGRAM – DEACON BOOSTER PUMPING STATION CHLORINE LINE RELOCATION

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: May 11, 2005
BY: Bill Richert, P. Eng.
TELEPHONE NO. (204) 284-0580

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20050301

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

B2. SUBMISSION DEADLINE

Revise: B2.1 The Submission Deadline is 12:00 noon Winnipeg time, May 19, 2005.

DRAWINGS

Drawing WY-C010-SK-1 is provided and forms part of this Addendum:

Replace Drawing 1-0601Y-C-C0010-001-00D with Drawing WY-C010-SK-1.

PART E – SPECIFICATIONS

E.2 EXCAVATION

Delete: E.2.1 Replace with:

E2.1 The Contractor shall use vacuum excavation methods on the east-west run of new piping. The 14 m long north-south run of new piping may be installed using a backhoe.

Add: E2.3 The excavation may follow the contour of the existing grade provided the minimum cover specified on Detail 1 of Drawing WY-C010-SK-1 is maintained.