



NOTE:

1. STEAM & RETURN TO RUN AS HIGH AS POSSIBLE.
2. ALL CHANGES OF DIRECTION TO BE MADE WITH SWING CONNECTIONS.
3. ALL DRAIN POINTS & UNIT VENTS ON THIS LEVEL TO HAVE BUCKET TRAPS.
4. STEAM & RETURN LINES TO RUN AS CLOSE TO OUTSIDE WALL AS POSSIBLE.

NOTE:

UNIT VENTERS IN ROOMS 130, 134, 133, 132, 128, 129, 130, 131 TO BE TRANE 1218-234 1140 RPM 1/2 HP.

Drawing 3-07-R0

REVISIONS			WINNIPEG ENTERPRISES CORP ARENA WOLEVER AVENUE	HEATING & VENTILATING	
NO.	DESCRIPTION	DATE		ICE LEVEL	
			THE CONTRACTOR SHALL CHECK ALL DIMENSIONS AND OTHER DATA FROM THE JOB AND REPORT ANY DISCREPANCY TO THE ARCHITECTS FOR ADJUSTMENT.		101360