



589-2005 ADDENDUM 1

RE-ROOFING OF THE NEWPCC MAIN BUILDING EXPANSION

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: October 7, 2005
BY: John Elias C.E.T.
TELEPHONE NO. (204) 986-4450

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20050506

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, October 13, 2005

PART E – SPECIFICATIONS

E2 APPLICABLE NATIONAL MASTERS SPECIFICATIONS (NMS)

- Delete: **2.5 ADHESIVE**
- .1 Adhesive for securing overlay board and insulation: asphalt extended vulcanized adhesive, two component unit, consisting of two liquids mixed on site to produce pourable adhesive
- Delete: **2.8 POLYSTYRENE INSULATION**
- .1 Extruded polystyrene (XPS) or Expanded polystyrene (EPS) insulation to CAN/ULC-S701, Type 2, 3 or 4, thickness 100 mm or,
- Add: **3.1 WORKMANSHIP**
- .3 Remove existing roofing and dispose of at a suitable landfill site.