



611-2005 ADDENDUM No 6

NORTH END WATER POLLUTION CONTROL CENTRE CENTRATE NUTRIENT TREATMENT – PHOSPHORUS REMOVAL FACILITY PROJECT

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: February 7, 2006
BY: Eric Hutchison P.Eng
TELEPHONE NO. (204) 477-5381

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20050301

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

ADD B16.4 TO READ:

The City intends to award this contract no later than April 10, 2006

PART D – SUPPLEMENTAL CONDITIONS

REVISE D12.1 TO READ:

The Contractor shall achieve Substantial Performance by October 18, 2006.

REVISE D13.1 TO READ:

The Contractor shall achieve Total Performance by November 3, 2006.

PART E – SPECIFICATIONS

Drawing CM1.01

CLARIFICATIONS

Provide self regulating heat trace cable for domestic water line with-in the Railcar Shelter. Heat trace cable to be secured to the under side of the domestic water lines. Insulation for the domestic water lines to be provided under Division 15.

Heat trace cable shall be connected to circuit PB-15 as indicated on Drawing CE3.01. Heat Trace to be as manufactured by Serge Baril Cat. No. 3 FPS 1.