



## 666-2005 ADDENDUM 1

### NEW CHEMICAL STORAGE WAREHOUSE – 620 TYNE AVENUE

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: December 1, 2005  
BY: Bob Long  
TELEPHONE NO. (204) 896-1209

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20050506

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.**

---

#### **PART E – SPECIFICATIONS**

Revise Section 13126, Clause 2.3.2 to read:

- 2.3.2 Exterior sheet-roof: factory preformed steel sheet galvalume from manufacturer's standard profiles. Include closures, gaskets, caulking, flashing and fasteners to effect weathertight installation. Cut ends of sheets square and clean. Minimum 0.607 mm (24 GA) base metal thickness.

#### **DRAWINGS**

- Replace Drawing 05-0107-12-C1 Sht2-R0 with Drawing 05-0107-12C1 Sht2-R1  
Replace Drawing 05-0107-12-A1 Sht3-R0 with Drawing 05-0107-12A1 Sht3-R1  
Replace Drawing 05-0107-12-S2 Sht5-R0 with Drawing 05-0107-12S2 Sht5-R1