



- DRAWING NOTES**
- ① SUPPLY AND INSTALL BIRD SCREEN WITH GRAVITY HOOD.
 - ② VENT STACK RISING THROUGH ROOF. SIZE OF RISER SHOWN. INCREASE RISER SIZE BY MINIMUM OF 1 PIPE SIZE AT ROOF PENETRATION. INSULATE RISER 1M DOWN FROM ROOF PENETRATION.
 - ③ COORDINATE LOCATION WITH ARCHITECTURAL. REFER TO ARCHITECTURAL DRAWINGS. SEE DETAIL ON DRAWING M7.02.
 - ④ REFER TO:

3
M7.05

- GENERAL NOTES**
1. COORDINATE WITH OTHER TRADES SO AS TO PREVENT CONFLICTS.
 2. SEE ROOF DETAIL ON DRAWING CM7.05.

① **PLAN VIEW – ROOF**
M4.02 SCALE 1:75



B.M. ELEV.	 <small>Earth Tech (Canada) Inc. Winnipeg, Manitoba 204.477.5381</small>	ENGINEER'S SEAL ORIGINAL SIGNED BY P.V. LAITINEN FEB. 18/05	 Winnipeg WATER AND WASTE DEPARTMENT
	DESIGNED BY: PL CHECKED BY: AMA DRAWN BY: DC, DL APPROVED BY: DT		NEWPCC – SECONDARY EFFLUENT UV DISINFECTION FACILITY
	HOR. SCALE: AS NOTED VERTICAL SCALE: AS NOTED	RELEASED FOR CONSTRUCTION BY: T. KJARTANSON DATE: 2005-02-18	MECHANICAL ROOF PLAN MECHANICAL PLAN
1 ISSUED FOR ADDENDUM 1 05/03/11 DC 0 ISSUED FOR TENDER 05/02/18 JEH	NO. REVISIONS DATE BY DATE 2004/12/08 DATE 2005-02-18	CONSULTANT DRAWING NO. 66303D-CM4.02	CITY FILE NUMBER SHEET 6 OF 18 CITY DRAWING NUMBER