




Rev.	Comments	Jumper or Internal Cable	Conductor #	Cable	Cable Information	
		Switch 1				
0	Primary Sodium Hypochlorite PLC		01	RJ-45	C-CP-J11-C01	4-Pair #24 AWG - Cat 5E TO CP-J11
0	Standby Sodium Hypochlorite PLC		02	RJ-45	C-CP-J11-C02	4-Pair #24 AWG - Cat 5E TO CP-J11
0	Spare		03			
0	Spare		04			
0	Spare		05			
0	Spare		06			
0	Plant Control Network Receive	PP1: 01	07-Rx			
0	Plant Control Network Transmit	PP1: 02	07-Tx			
0	Plant Control Network Receive	PP1: 14	08-Rx			
0	Plant Control Network Transmit	PP1: 13	08-Tx			
		Switch 2				
0			01	RJ-45	C-WTPWSJ11 01-C01	4-Pair #24 AWG - Cat 5E TO WTPWSJ11 01
0	Spare		02			
0	Spare		03			
0	Spare		04			
0	Spare		05			
0	Spare		06			
0	Plant Monitoring Network Receive	PP1: 05	07-Rx			
0	Plant Monitoring Network Transmit	PP1: 06	07-Tx			
0	Plant Monitoring Network Receive	PP1: 18	08-Rx			
0	Plant Monitoring Network Transmit	PP1: 17	08-Tx			

<b>NOTES:</b> 1. Panel and Cabling are not in Contract 742-2005. Drawing Issued for Information Only.	B.M. ELEV.			 		<b>ENGINEER'S SEAL</b>  ORIGINAL SIGNED BY S.W. TORMEY 2006/03/29  CONSULTANT DRAWING NO. WH-A0521	<b>THE CITY OF WINNIPEG</b> <b>WATER AND WASTE DEPARTMENT</b> <b>ENGINEERING DIVISION</b>				
				DESIGNED BY	SWT		CHECKED BY	SWT	WATER TREATMENT PLANT PLANT UTILITIES MECHANICAL AND ELECTRICAL	CITY FILE NUMBER	
				DRAWN BY	SWT		APPROVED BY	AHL		SHEET 21 OF 88	
	1	742-2005 ADDENDUM 6	06/05/25	SCALE:	NTS		RELEASED FOR CONSTRUCTION BY:	R. SOROKOWSKI		CITY DRAWING NUMBER	
	0	ISSUED FOR TENDER	06/03/29							1-0601H-J-A0521-001-01B	
	NO.	REVISIONS	DATE	BY	DATE	2006/03/29	DATE	2006/03/29			



Certificate of Authorization  
Earth Tech Canada Inc.  
No. 730 Expiry: April 30, 2006.