LCP-F02A	Filters 5-8 Communication Panel					
Rev.	Comments	Jumper or Internal Cable		Conductor #	Cable	Cable Infor
			PP1			
0	Plant Control Network Receive	PP1: 13	01	01	C-LCP-F02A-C01	12-Strand 6
0	Plant Control Network Transmit	PP1: 14	02	02		
0	Remote I/O Network Receive	RIO Repeater: 01-Rx	03	03		
0	Remote I/O Network Transmit	RIO Repeater: 01-Tx	04	04		
0	Plant Monitoring Network Receive	PP1: 17	05	05		
0	Plant Monitoring Network Transmit	PP1: 18	06	06		
0	Spare		07	07		
0	Spare		08	08		
0	Spare		09	09		
0	Spare		10	10		
0	Spare		11	11		
0	Spare		12	12		
0	Plant Control Network Transmit	PP1: 01	13	01	C-LCP-F01A-C01	12-Strand 6
0	Plant Control Network Receive	PP1: 02	14	02		
0	Remote I/O Network Transmit	RIO Repeater: 02-Tx	15	03		
0	Remote I/O Network Receive	RIO Repeater: 02-Rx	16	04		
0	Plant Monitoring Network Transmit	PP1: 05	17	05		
0	Plant Monitoring Network Receive	PP1: 06	18	06		
0	Spare		19	07		
0	Spare		20	08		
0	Spare		21	09		
0	Spare		22	10		
0	Spare		23	11		
0	Spare		24	12		

NOTES:	B.M. ELEV.			CH2MHILL Frederickson Cooper ARCHITECTS		Earth A Tyco Internat	Tech lional Ltd. Company	ENGINEER'S SEAL ORIGINAL SIGNED BY S.W. TORMEY 2006/03/29	THE water engine	
			DESIGNED BY SWT	CHECKED BY SWT	WATER TREAT PLANT U					
Certificate of Authorization					DRAWN BY	SWT	APPROVED BY	AHL		MECHANICAL A
Earth Tech Canada Inc.	1	742-2005 ADDENDUM 6	06/05/25	SWT	SCALE: NTS	NTC	RELEASED FOR CONSTRUCTION BY:			AUTOMATI
No. 730 Expiry: April 30, 2006.	0	ISSUED FOR TENDER	06/03/29	SWT		NIS	R. SOROKOWSKI	CONSULTANT DRAWING NO.	PLANT COMMUN	
I J. I HARA	NO.	REVISIONS	DATE	BY	DATE 2	2006/03/29	DATE	2006/03/29	WH-A0533	TERMINATIO

Thursday, May 25, 2006

nformation

nd 62.5/125 um Multi-mode TO CP-C11A

nd 62.5/125 um Multi-mode TO LCP-F01A

E CITY OF WINNIPEG or and waste department neering division								
ATMENT PLANT `UTILITIES AND ELECTRICAL	CITY FILE NUMBER SHEET OF 88							
TION / I AND C UNICATION CABLE ION DIAGRAMS	CITY DRAWING NUMBER 1-0601H-J-A0533-001-01B							