Dewatering Pump Station Control Panel					
Comments	Jumper or Internal Cable	Conductor #	Cable	Cable Information	
	F	PP1			
Plant Control Network Receive			C-LCP-L11A-C01	12-Strand 62.5/125 um Multi-mode TO LCP-H10A	
Plant Control Network Transmit	Switch 1: 07-Tx	02 02			
		03 03			
		04			
		05 05			
		06 06			
		07 07			
		08 08			
		09 09			
		10 10			
		11 11			
		12 12			
Plant Control Network Transmit	Switch 1: 08-Tx	13 01	C-LCP-H10A-C02	12-Strand 62.5/125 um Multi-mode TO LCP-H10A	
Plant Control Network Receive	Switch 1: 08-Rx	14 02			
		15 03			
		16 04			
		17 05			
		18 06			
		19 07			
		20 08			
		21 09			
		22 10			
		23 11			
		24 12			
	Plant Control Network Receive Plant Control Network Transmit	Plant Control Network Transmit Plant Control Network Transmit Switch 1: 07-Tx Plant Control Network Transmit Plant Control Network Transmit Switch 1: 08-Tx Plant Control Network Receive Switch 1: 08-Rx	Comments Switch 1: 07-Rx	Number of Internal Cable Conduct # Cable	

NOTES: 1. Panel and Cabling are not in Contract 742-2005. Drawing Issued for Information Only.	B.M. ELEV.			CH2MHILL Frederickson Cooper ARCHITECTS		EarthTech A Tyco International Ltd. Company		ENGINEER'S SEAL ORIGINAL SIGNED BY	THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION	
				DESIGNED BY DRAWN BY	SWT	CHECKED BY SWT APPROVED RY AHL	S.W. TORMEY 2006/03/29	WATER TREATMENT PLANT PLANT UTILITIES MECHANICAL AND ELECTRICAL	CITY FILE NUMBER SHEET OF 40 88	
Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006.	1 742-2005 ADDENDUM (0 ISSUED FOR TENDER NO. REVISIONS	06/05/2 06/03/2 DATE	9 SWT	SCALE: DATE	NTS 2006/03/29	RELEASED FOR CONSTRUCTIO R. SOROK DATE 20	ON BY:	CONSULTANT DRAWING NO. WH-A0540	AUTOMATION / I AND C PLANT COMMUNICATION CABLE TERMINATION DIAGRAMS	CITY DRAWING NUMBER 1-0601H-J-A0540-001-01B