Jumper or Internal Cable	Switch 1	Conductor #	Cable	Cable Information	
	01	5.45			
	· · ·	RJ-45	C-LCP-P060A-C01	4-Pair #24 AWG - Cat 5E TO LCP-P060A	
	02	RJ-45 —	C-LCP-P050A-C01	4-Pair #24 AWG - Cat 5E TO LCP-P050A	
	03	RJ-45	C-LCP-P040A-C01	4-Pair #24 AWG - Cat 5E TO LCP-P040A	
	04				
	05				
	06				
	07				
	08	RJ-45	C-LCP-P12A-C01	4-Pair #24 AWG - Cat 5E TO CP-P32	
		03 04 05 06 07	03 RJ-45	03 RJ-45 C-LCP-P040A-C01 04 05 06 07	03

NOTES: 1. Panel Supplied by the City.	B.M. ELEV.			CH2MHILL Frederickson Cooper ARCHITECTS EarthTech ATyco International Ltd. Compa			ENGINEER'S SEAL ORIGINAL SIGNED BY	THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION		
				DESIGNED BY	SWT	CHECKED BY	SWT	S.W. TORMEY 2006/03/29	WATER TREATMENT PLANT PLANT UTILITIES	CITY FILE NUMBER
APEGIN				DRAWN BY	SWT	APPROVED BY	AHL		MECHANICAL AND ELECTRICAL	SHEET OF 88
Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006.	1 742-2005 ADDENDUM 0 ISSUED FOR TENDER		5 SWT 9 SWT	SCALE:	NTS	RELEASED FOR CONSTRUCTION R. SOROK	ON BY:	CONSULTANT DRAWING NO.	AUTOMATION / I AND C PLANT COMMUNICATION CABLE	CITY DRAWING NUMBER
25phy; 14p.1100, 2000.	NO. REVISIONS	DATE	BY	DATE	2006/03/29	DATE 2	006/03/29	WH-A0549	TERMINATION DIAGRAMS	1-0601H-J-A0549-001-01B