



Rev.	Comments	Jumper or Internal Cable	Conductor #	Cable	Cable Information
PP1					
0	Plant Control Network Receive	PP1: 13	01	C-LCP-T11A-C01	12-Strand 62.5/125 um Multi-mode TO LCP-H10A
0	Plant Control Network Transmit	PP1: 14	02		
0	Remote I/O Network Receive	RIO Repeater: 01-Rx	03		
0	Remote I/O Network Transmit	RIO Repeater: 01-Tx	04		
0	Plant Monitoring Network Receive	Switch 1: 07-Rx	05		
0	Plant Monitoring Network Transmit	Switch 1: 07-Tx	06		
0	Spare		07		
0	Spare		08		
0	Spare		09		
0	Spare		10		
0	Spare		11		
0	Spare		12		
0	Plant Control Network Transmit	PP1: 01	13	C-CP-H11A-C01	12-Strand 62.5/125 um Multi-mode TO CP-H11A
0	Plant Control Network Receive	PP1: 02	14		
0	Spare		15		
0	Spare		16		
0	Plant Monitoring Network Transmit	Switch 1: 08-Tx	17		
0	Plant Monitoring Network Receive	Switch 1: 08-Rx	18		
0	Spare		19		
0	Spare		20		
0	Spare		21		
0	Spare		22		
0	Spare		23		
0	Spare		24		

NOTES: 1. Panel and Cabling are not in Contract 742-2005. Drawing Issued for Information Only.	B.M. ELEV.			 		ENGINEER'S SEAL ORIGINAL SIGNED BY S.W. TORMEY 2006/03/29 CONSULTANT DRAWING NO. WH-A0563	THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION			
				DESIGNED BY	SWT		CHECKED BY	SWT	WATER TREATMENT PLANT	CITY FILE NUMBER
				DRAWN BY	SWT		APPROVED BY	AHL	PLANT UTILITIES	SHEET 63 OF 88
				SCALE:	NTS		RELEASED FOR CONSTRUCTION BY:	MECHANICAL AND ELECTRICAL		
			NO.	REVISIONS	DATE	BY	DATE	2006/03/29	DATE	2006/03/29
								AUTOMATION / I AND C	CITY DRAWING NUMBER	
								PLANT COMMUNICATION CABLE	1-0601H-J-A0563-001-01B	
								TERMINATION DIAGRAMS		

