




REV.	CABLE TAG	CABLE SPECIFICATIONS	LENGTH (m)	FROM	TO	DESCRIPTION	REMARKS
0	C-CP-H30-C03	1-Coaxial RG-6		CP-H30A Plant Master PLC Communication Panel	CP-H30 Main Plant PLC Electrical 3rd	Plant Master Remote I/O	
0	C-CP-H31A-C01	12-Strand 62.5/125 um Multi-mode		CP-P31A DAF Communication Panel	CP-H31A Primary Server Room Communication Panel	Plant Communication	
0	C-CP-H32A-C01	12-Strand 62.5/125 um Multi-mode		CP-H30A Plant Master PLC Communication Panel	CP-H32A Backup Server Room Communication Panel	Plant Communication	
0	C-CP-J11A-C01	12-Strand 62.5/125 um Multi-mode		LCP-T11A Clearwell Communication Panel	CP-J11A Sodium Hypochlorite Communication Panel	Plant Communication	Not in Contract 742-2005.
0	C-CP-J11-C01	4-Pair #24 AWG - Cat 5E		CP-J11A Sodium Hypochlorite Communication Panel	CP-J11	Primary Sodium Hypochlorite PLC Plant Control Network Cable	Not in Contract 742-2005.
0	C-CP-J11-C02	4-Pair #24 AWG - Cat 5E		CP-J11A Sodium Hypochlorite Communication Panel	CP-J11	Standby Sodium Hypochlorite PLC Plant Control Network Cable	Not in Contract 742-2005.
0	C-CP-O11A-C01	12-Strand 62.5/125 um Multi-mode		CP-H30A Plant Master PLC Communication Panel	CP-O11A Liquid Oxygen Communication Panel	Plant Communication	Not in Contract 742-2005.
0	C-CP-O11-C01	4-Pair #24 AWG - Cat 5E		CP-O11A Liquid Oxygen Communication Panel	CP-O11 PLC Cabinet LOX Area 1st	Primary Liquid Oxygen PLC Plant Control Network Cable	Not in Contract 742-2005.
0	C-CP-O11-C02	4-Pair #24 AWG - Cat 5E		CP-O11A Liquid Oxygen Communication Panel	CP-O11 PLC Cabinet LOX Area 1st	Standby Liquid Oxygen PLC Plant Control Network Cable	Not in Contract 742-2005.
0	C-CP-O30A-C01	12-Strand 62.5/125 um Multi-mode		LCP-R21A Residuals Communication Panel	CP-O30A Ozone Communication Panel	Plant Communication	
0	C-CP-O30-C01	4-Pair #24 AWG - Cat 5E		CP-O30A Ozone Communication Panel	CP-O30 Ozone Control PLC Panel Supply	Primary Ozone Master PLC Plant Control Network Cable	
0	C-CP-O30-C02	4-Pair #24 AWG - Cat 5E		CP-O30A Ozone Communication Panel	CP-O30 Ozone Control PLC Panel Supply	Standby Ozone Master PLC Plant Control Network Cable	
0	C-CP-O31-C01	4-Pair #24 AWG - Cat 5E		CP-O30A Ozone Communication Panel	CP-O31	Ozone Generator 1 PLC Plant Control Network Cable	
0	C-CP-O32-C01	4-Pair #24 AWG - Cat 5E		CP-O30A Ozone Communication Panel	CP-O32	Ozone Generator 2 PLC Plant Control Network Cable	
0	C-CP-O33-C01	4-Pair #24 AWG - Cat 5E		CP-O30A Ozone Communication Panel	CP-O33	Ozone Generator 3 PLC Plant Control Network Cable	

NOTES:   <p>Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006.</p>	B.M. ELEV.		 		ENGINEER'S SEAL		<b>THE CITY OF WINNIPEG</b> <b>WATER AND WASTE DEPARTMENT</b> <b>ENGINEERING DIVISION</b>	
			DESIGNED BY SWT		CHECKED BY SWT			
			DRAWN BY SWT		APPROVED BY AHL		CONSULTANT DRAWING NO. WH-A0602	
	1 742-2005 ADDENDUM 6 06/05/25 SWT		SCALE: NTS		RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI			
	0 ISSUED FOR TENDER 06/03/29 SWT						CITY FILE NUMBER SHEET 2 OF 11 CITY DRAWING NUMBER 1-0601H-K-A0602-001-01B	
NO. REVISIONS		DATE BY		DATE 2006/03/29		DATE 2006/03/29		

Thursday, May 25, 2006