




REV.	CABLE TAG	CABLE SPECIFICATIONS	LENGTH (m)	FROM	TO	DESCRIPTION	REMARKS
0	C-CP-P31A-C01	12-Strand 62.5/125 um Multi-mode		CP-H32A Backup Server Room Communication Panel	CP-P31A DAF Communication Panel	Plant Communication	
0	C-CP-P31-C01	4-Pair #24 AWG - Cat 5E		CP-P31A DAF Communication Panel	CP-P31 DAF Basins 1-4 Control Panel	DAF Control	
0	C-CP-P32-C01	4-Pair #24 AWG - Cat 5E		CP-P31A DAF Communication Panel	CP-P32 DAF Basins 5-8 Control Panel	DAF Control	
0	C-JT-H951A-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H951A	SWGR 1A Power Meter Comm. Cable	
0	C-JT-H951B-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H951B	SWGR 1B Power Meter Comm. Cable	
0	C-JT-H952A-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H952A	MCC 1A Power Meter Comm. Cable	
0	C-JT-H952B-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H952B	MCC 1B Power Meter Comm. Cable	
0	C-JT-H953A-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H953A	MCC 2A Power Meter Comm. Cable	
0	C-JT-H953B-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H953B	MCC 2B Power Meter Comm. Cable	
0	C-JT-H954A-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H954A	MCC 3A Power Meter Comm. Cable	
0	C-JT-H954B-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H954B	MCC 3B Power Meter Comm. Cable	
0	C-JT-H961A-C01	4-Pair #24 AWG - Cat 5E		LCP-S11A Bulk Chemical Communication Panel	JT-H961A	SWGR 2A Power Meter Comm. Cable	Not in Contract 742-2005.
0	C-JT-H961B-C01	4-Pair #24 AWG - Cat 5E		LCP-S11A Bulk Chemical Communication Panel	JT-H961B	SWGR 2B Power Meter Comm. Cable	Not in Contract 742-2005.
0	C-JY-H951A-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H951A	SWGR 1A Protection Relay Comm. Cable	
0	C-JY-H951B-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H951B	SWGR 1B Protection Relay Comm. Cable	

NOTES:  <p>Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006.</p>	B.M. ELEV.		 		ENGINEER'S SEAL ORIGINAL SIGNED BY S.W. TORMEY 2006/03/29 CONSULTANT DRAWING NO. WH-A0603	THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION			
			DESIGNED BY	SWT		CHECKED BY	SWT	WATER TREATMENT PLANT PLANT UTILITIES MECHANICAL AND ELECTRICAL	CITY FILE NUMBER
			DRAWN BY	SWT		APPROVED BY	AHL		SHEET 3 OF 11
	1	742-2005 ADDENDUM 6	06/05/25	SWT		SCALE:	RELEASED FOR CONSTRUCTION BY:		CITY DRAWING NUMBER
	0	ISSUED FOR TENDER	06/03/29	SWT		NTS	R. SOROKOWSKI		1-0601H-K-A0603-001-01B
	NO. REVISIONS	DATE	BY	DATE	2006/03/29	DATE	2006/03/29		

Thursday, May 25, 2006