





REV.	CABLE TAG	CABLE SPECIFICATIONS	LENGTH (m)	FROM	TO	DESCRIPTION	REMARKS
0	C-LCP-P31-C01	4-Pair #24 AWG - Cat 5E		CP-P31 DAF Basins 1-4 Control Panel	LCP-P31 DAF Basin 1 VFD Control Panel	DAF Basin 1 VFD Control	
0	C-LCP-P32-C01	4-Pair #24 AWG - Cat 5E		CP-P31 DAF Basins 1-4 Control Panel	LCP-P32 DAF Basin 2 VFD Control Panel	DAF Basin 2 VFD Control	
0	C-LCP-P33-C01	4-Pair #24 AWG - Cat 5E		CP-P31 DAF Basins 1-4 Control Panel	LCP-P33 DAF Basin 3 VFD Control Panel	DAF Basin 3 VFD Control	
0	C-LCP-P34-C01	4-Pair #24 AWG - Cat 5E		CP-P31 DAF Basins 1-4 Control Panel	LCP-P34 DAF Basin 4 VFD Control Panel	DAF Basin 4 VFD Control	
0	C-LCP-P35-C01	4-Pair #24 AWG - Cat 5E		CP-P32 DAF Basins 5-8 Control Panel	LCP-P35 DAF Basin 5 VFD Control Panel	DAF Basin 5 VFD Control	
0	C-LCP-P36-C01	4-Pair #24 AWG - Cat 5E		CP-P32 DAF Basins 5-8 Control Panel	LCP-P36 DAF Basin 6 VFD Control Panel	DAF Basin 6 VFD Control	
0	C-LCP-P37-C01	4-Pair #24 AWG - Cat 5E		CP-P32 DAF Basins 5-8 Control Panel	LCP-P37 DAF Basin 7 VFD Control Panel	DAF Basin 7 VFD Control	
0	C-LCP-P38-C01	4-Pair #24 AWG - Cat 5E		CP-P32 DAF Basins 5-8 Control Panel	LCP-P38 DAF Basin 8 VFD Control Panel	DAF Basin 8 VFD Control	
0	C-LCP-R21A-C01	12-Strand 62.5/125 um Multi-mode		LCP-F01A Filters 1-4 Communication Panel	LCP-R21A Residuals Communication Panel	Plant Communication	
0	C-LCP-R21-C01	1-Coaxial RG-6		LCP-R21A Residuals Communication Panel	LCP-R21	Residuals Remote I/O	
0	C-LCP-S11A-C01	12-Strand 62.5/125 um Multi-mode		CP-J11A Sodium Hypochlorite Communication Panel	LCP-S11A Bulk Chemical Communication Panel	Plant Communication	Not in Contract 742-2005.
0	C-LCP-S11-C01	1-Coaxial RG-6		LCP-S11A Bulk Chemical Communication Panel	LCP-S11	Bulk Chemical Remote I/O	Not in Contract 742-2005.
0	C-LCP-T11A-C01	12-Strand 62.5/125 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	LCP-T11A Clearwell Communication Panel	Plant Communication	Not in Contract 742-2005.
0	C-LCP-T11A-C02	12-Strand 62.5/125 um Multi-mode		CP-H11A Generator Communication Panel	LCP-T11A Clearwell Communication Panel	Plant Communication	Not in Contract 742-2005.
0	C-LCP-T11-C01	1-Coaxial RG-6		LCP-T11A Clearwell Communication Panel	LCP-T11	Clearwell Remote I/O	Not in Contract 742-2005.

NOTES:  Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006.	B.M. ELEV.		  		ENGINEER'S SEAL		THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION	
			DESIGNED BY SWT		CHECKED BY SWT			
			DRAWN BY SWT		APPROVED BY AHL		CITY FILE NUMBER SHEET 6 OF 11	
	1 742-2005 ADDENDUM 6 06/05/25 SWT		SCALE: NTS		RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI		AUTOMATION / I AND C PLANT COMMUNICATION CABLES CABLE LIST	
	0 ISSUED FOR TENDER 06/03/29 SWT		NO. REVISIONS		DATE 2006/03/29		CITY DRAWING NUMBER 1-0601H-K-A0606-001-01B	

Thursday, May 25, 2006