



PRIMARY SLUDGE PUMP 1
 EQUIP. NO.: P-250-SLP
 SPEC: 11320
 TYPE: RECESSED IMPELLER CENTRIFUGAL
 CAPACITY: 10-20 L/s
 HEAD: 2.2-4.3 m
 POWER: 3.75 kw

PRIMARY SLUDGE PUMP 2
 EQUIP. NO.: P-260-SLP
 SPEC: 11320
 TYPE: RECESSED IMPELLER CENTRIFUGAL
 CAPACITY: 10-20 L/s
 HEAD: 2.2-4.3 m
 POWER: 3.75 kw



		ENGINEER'S SEAL ORIGINAL SIGNED BY S.W. TORMEY 2006/04/26			
DESIGNED BY: YL/EVS CHECKED BY: KM/ST DRAWN BY: PY/PPL APPROVED BY: JEH		S.W. TORMEY 2006/04/26		WEWPC BIOLOGICAL NUTRIENT REMOVAL UPGRADE CONTRACT 3	
HOR. SCALE: NONE VERTICAL SCALE:		RELEASED FOR CONSTRUCTION BY: J. VEILLEUX		CITY FILE NUMBER SHEET OF CITY DRAWING NUMBER	
NO. REVISIONS DATE BY		DATE 2005/07/06 DATE 2006/04/26		PROCESS AREA P - PRIMARY CLARIFIERS PRIMARY SLUDGE PUMPING - P&ID	