



- ### DRAWING NOTES
- 1 HOUSE KEEPING PADS FOR T600-MUA & T605-MUA.
 - 2 250mm COMBUSTION AIR DUCTS FOR TWO BOILERS.
 - 3 40mm COMPRESSED AIR PIPE TO DAF TANKS.
 - 4 EXHAUST DUCT FROM DAF TANKS.
 - 5 REMOVABLE PIECE.
 - 6 360mm T650-GH AND T655-GH BOILER FLUE VENT.
 - 7 FOR CONTINUATION SEE DRAWING HM1.01.
 - 8 T600-SF-UFD, T600-EF-UFD, T605-SF-UFD & T605-EF-UFD.
 - 9 PROVIDE 50mm EXTERNAL THERMAL INSULATION FOR A FULL DISTANCE.
 - 10 400mm GOOSENECK INTAKE ON ROOF c/w MOTORIZED DAMPER.
 - 11 REFRIGERANT LINES DOWN FROM CONDENSING UNIT TO COOLING COIL.
 - 12 FLEXIBLE CONNECTION. TYPICAL.
 - 13 400x400 RELIEF AIR DUCT RISING TO RELIEF AIR HOOD ON ROOF c/w BACK DRAFT DAMPER. TERMINATE INTAKE OPENING APPROX. 600mm BELOW ROOF DECK.
 - 14 REFER TO DRAWING HM2.01 FOR CONTINUATION.
 - 15 EXTEND GAS PRV VENT UP THROUGH PITCH POCKET ON ROOF.

- ### GENERAL NOTES
1. COORDINATE WITH OTHER TRADES SO AS TO PREVENT CONFLICTS.
 2. ALL DUCTWORK SHALL BE SUPPORTED AND SUSPENDED AS PER SPECIFICATIONS AND LOCAL CODES (SEE DETAILS).
 3. ALL DUCTWORK TO BE STAINLESS STEEL CONSTRUCTION.



 A Tyco International Ltd. Company		ENGINEER'S SEAL ORIGINAL SIGNED BY A. BURACHYNSKY 2006/04/26	
DESIGNED BY	PVL/LJW	CHECKED BY	PVL
DRAWN BY	LJW	APPROVED BY	JEH
HOR. SCALE: 1:50 VERTICAL SCALE:		RELEASED FOR CONSTRUCTION BY: J. VEILLEUX	
NO. REVISIONS	DATE	BY	DATE
01	21-2006 ADDENDUM 3	06/05/19	LJW
00	ISSUED FOR TENDER	06/04/26	DC
2006/01/04		2006/04/26	

THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION		CITY FILE NUMBER
WEWPC BIOLOGICAL NUTRIENT REMOVAL UPGRADE CONTRACT 3		SHEET OF
MECHANICAL AREA T - DAF THICKENER BUILDING MEZZANINE VENTILATION PLAN		CITY DRAWING NUMBER