



# ADDENDUM NO. 1 BID OPPORTUNITY NO. 25-2006

## 2005 COMBINED SEWER RENEWALS AND SEWER REPAIRS – CONTRACT NO. 19

### URGENT

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: February 9, 2006  
BY: Stacy Cournoyer, P. Eng.  
TELEPHONE NO. (204) 986-2142

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: 20040128

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid Submission non-responsive.**

---

### PART A – BID SUBMISSION

Replace 25-2006\_Bid\_Submission with 25-2006\_Addendum\_1-Bid\_Submission. The following is a summary of changes incorporated in the replacement Bid Submission:

Form B (R1): Delete Part G: Clifton Street - Sewer ID S-MA20009317

### PART D – SUPPLEMENTAL CONDITIONS

Revise D18.4 (d) to read: Spruce Street, Arlington Street, Ashburn Street, Doreen Street, Dundas Street, Ingersoll Street, St. James Street, Strathcona Street, Tefler Street

### PART E – SPECIFICATIONS

Revise E1.2 Applicable Specifications, Standard Details and Drawings. The following is a summary of changes incorporated in the revision:

Delete Drawing No. 05743 Clifton Street N – MH at W Leg to 1st MH E of W Leg

Revise E4.1.1 (b) to read: Asphalt and concrete pavements (Edmonton Street and Erin Street): minimum 100 millimetre thick layer of "Concrete For Temporary Restoration of Utility Pavement Cuts" as specified in CW 3310.

Asphalt and Concrete pavements (remaining streets): minimum 150 millimetre thick layer of cement-stabilized fill.