



1  
E3.03  
CENTRATE WAS TIE-IN LOCATION SAMPLE PUMP AND FRIDGE. REFER TO DETAIL

2-2/C#12 FROM SECONDARY ELECTRICAL ROOM TO NEW RECEPTACLES FOR SAMPLING EQUIPMENT CONTRACTOR SHALL DETERMINE CABLE ROUTE ON-SITE

APPROXIMATE LOCATION OF SECOND FLOOR SLUDGE DEWATERING ELECTRICAL ROOM. PROVIDE NEW:  
ONE (1) 1Ø, 208V, 0.5HP MOTOR STARTER.  
ONE (1) 15A-2P BREAKER AND TWO (2) 15A-1P BREAKERS IN EXISTING PANELS FOR NEW SAMPLING EQUIPMENT.

1  
E3.03  
CENTRATE AND FLUSHING WATER TIE-IN LOCATION SAMPLE PUMP, SAMPLER AND FRIDGE. REFER TO DETAIL

- SODA ASH FACILITY
- METHANOL STORAGE TANKS
- NITROGEN REMOVAL FACILITY
- FACILITY TRANSFORMERS
- SURFACE DUCT BANK MARKERS TYPICAL

**SITE PLAN**  
SCALE: N.T.S.

<p>Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2007</p>	B.M. ELEV.	<p>A Tyco International Ltd. Company</p>	ENGINEER'S SEAL	<p>THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION</p>	
			DESIGNED BY PS		ORIGINAL SIGNED BY P. STRYK
			DRAWN BY CPG		2005/05/15
			SCALE: NTS		CONSULTANT DRAWING NO. E1.02
	01 291-2006 ADDENDUM 3 06/07/12 CPG	CHECKED BY GSN			
	00 ISSUED FOR TENDER 06/05/15 CPG	APPROVED BY JEH			
	NO. REVISIONS DATE BY	RELEASED FOR CONSTRUCTION BY: K. MARTENS			
	DATE 2006/02/23 DATE 2006/05/23				