



LOWER LEVEL PLAN  
SCALE 1:125

- NOTES:**
- GLASS LINED PLUG VALVE WITH STEM WITH REMOVABLE OPERATOR EXTENDING TO SBR COVER WITH CORROSION PROOF EPOXY COATING. PROVIDE SUPPORT FOR VALVE.
  - ALL METAL PARTS BENEATH SBR COVERS USED FOR PIPE SUPPORT INCLUDING ANCHORS, RODS AND CLAMPS TO BE SS316. SUBMERGED METAL PARTS IN EQUALIZATION TANK USED FOR PIPE SUPPORT INCLUDING ANCHORS, RODS AND CLAMPS TO BE SS316.
  - DECANTERS SUPPLIED UNDER A SEPARATE CONTRACT. INSTALL DECANTERS AS PART OF THIS CONTRACT. COORDINATE EXACT DIMENSIONS WITH DECANTER SUPPLIER.
  - PROVIDE TEN WATER NOZZLES, EQUALLY SPACED. NOZZLES TO BE RAIN-BIRD 2045-PJ MAX BIRD 25 PSI.
  - FOR PIPING CONTINUATION OUTSIDE OF STRUCTURE REFER TO CIVIL DRAWINGS.
  - PROVIDE VICTAULIC FLANGES ON PIPES LOCATED ABOVE THE HIGH WATER LEVEL.
  - REFER TO DRAWING P14.03 FOR ELEVATIONS OF ALL PIPE PENETRATIONS THROUGH THIS WALL.

<p>Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2007</p>	B.M. ELEV.	<p>A Tyco International Ltd. Company</p>	ENGINEER'S SEAL	<p>THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION</p>												
			DESIGNED BY: YL		ORIGINAL SIGNED BY: J.E. HUTCHISON											
			CHECKED BY: SB		DATE: 2006/05/15											
			APPROVED BY: JEH		CONSULTANT DRAWING NO. P13.01											
	<table border="1"> <tr> <td>02</td> <td>291-2006 ADDENDUM 6</td> <td>06/07/26</td> <td>SRP</td> </tr> <tr> <td>01</td> <td>291-2006 ADDENDUM 3</td> <td>06/07/12</td> <td>LAE</td> </tr> <tr> <td>00</td> <td>ISSUED FOR TENDER</td> <td>06/05/15</td> <td>GLG</td> </tr> </table>	02	291-2006 ADDENDUM 6	06/07/26	SRP	01	291-2006 ADDENDUM 3	06/07/12	LAE	00	ISSUED FOR TENDER	06/05/15	GLG	SCALE: 1:125	RELEASED FOR CONSTRUCTION BY: K. MARTENS	CITY FILE NUMBER
02	291-2006 ADDENDUM 6	06/07/26	SRP													
01	291-2006 ADDENDUM 3	06/07/12	LAE													
00	ISSUED FOR TENDER	06/05/15	GLG													
	NO. REVISIONS	DATE	DATE	2006/01/16	DATE	2006/05/15	SHEET OF									
							CITY DRAWING NUMBER									
							1-0101C-A-P0001-001-020									