



ADDENDUM 5 BID OPPORTUNITY 35-2006

WINNIPEG WATER TREATMENT PROGRAM – DEACON BOOSTER PUMPING STATION UPGRADE

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: August 14, 2007

BY: Bill Richert, P. Eng.

TELEPHONE NO. (204) 986-6053

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20050506

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Section 16120

- Revise 1.1.1 to read: Complete supply, installation and termination of 4160V power cables with 5kV 133% insulation rating for the temporary jumper and from new switchgear components to the loads.
- Add 1.1.3: Termination of City supplied 4160V shielded power cables with 8kV 133% insulation rating.
- Delete 2.1.1.3