



ADDENDUM 1 BID OPPORTUNITY 49-2006

WINNIPEG WATER TREATMENT PROGRAM – SUPPLY OF ONSITE HYPOCHLORITE GENERATION EQUIPMENT

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: March 31, 2006
BY: Bill Richert, P. Eng.
TELEPHONE NO. (204) 986-6053

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20050506

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART A – BID SUBMISSION

Replace: 49-2006-Bid_Submission with 49-2006_Addendum_1-Bid_Submission. Form G2 has been replaced by Form G2(R1).

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m., Winnipeg time, April 18, 2006.

PART E – SPECIFICATIONS

Section 11242

Revise: 2.3.1.3.4 to read: Chlorine residual 5 mg/L (max), 3 mg/L (average) as chloramines.

Revise: 2.3.2.1 to read: The softener vessels material shall be polyethylene and reinforced fiberglass.

Revise: 2.9.12.3 to read: The tubular cells shall be factory tested to a minimum of 350 kPa, for a period of 30 minutes, prior to final assembly and shipment

Revise: 2.11.3.3 to read: Pump connections shall be 150# ANSI standard flange connections in PVC or approved equal

Revise: 2.11.3.6 to read: Pump rotor shall be Hastelloy or equivalent. Rollers shall be cast iron on heavy-duty ball-bearings. Sliding shoes may be used in place of rollers.

Delete: 2.11.4.1

Section 13205

Delete: 2.2.1.7

Add: 2.3.2.14 Field joining of fiberglass reinforced tanks, components, features or fittings is not acceptable.

Section 16015

Revise: 1.3.2 to read: External conduit and wiring between separate equipment/skid packages will be supplied and installed by the Installation Contractor.