CP-H11A	Generator Communication Panel					
Rev.	Comments	Jumper or Internal Cable	Conductor #	Cable	Cable Information	
		PP	1			
0	Plant Control Network Receive	Switch 1: 07 01	01	C-CP-H11A-C01	24-Strand 50/125/250 um Multi-mode TO LCP-T11A	
0	Plant Control Network Transmit	Switch 1: 07 02	2 02 —			
2	Remote I/O Network Receive	RIO Repeater 1: 01 03	3 03			
2	Remote I/O Network Transmit	RIO Repeater 1: 01 04	1 04			
)	Plant Monitoring Network Receive	Switch 2: 07 05	5 05			
)	Plant Monitoring Network Transmit	Switch 2: 07 06	06			
0	Spare	07	7 07 —			
)	Spare	30	08			
3	City of Winnipeg LAN	09	09			
3	City of Winnipeg LAN	10	10			
3	Fire Alarm	11	11			
3	Fire Alarm	12	2 12			
3	Security	13	3 13			
3	Security	14	14			
2	Spare	15	5 15			
2	Spare	16	3 16 —			
2	Spare	17	7 17			
2	Spare	18	3 18			
2	Spare	19	19			
2	Spare	20	20			
2	Spare	21	21			
2	Spare	22	2 22			
2	Spare	23	3 23			
2	Spare	24	1 24			

NOTES: 1. Panel and Cabling are not in Contract 742-2005. Drawing Issued for Information Only. 2. Panel and Cabling are in Contract 498-2006.	B.M. ELEV.			CH2MHILL Frederickson Cooper ARCHITECTS EarthTech Also international life Company		Tech al ttd. Company	ENGINEER'S SEAL ORIGINAL SIGNED BY	THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION			
	4	498-2006 ADDENDUM 2 FOR CONSTRUCTION	06/09/22			SWT	CHECKED BY	SWT	S.W. TORMEY 2006/03/29	WATER TREATMENT PLANT PLANT UTILITIES	CITY FILE NUMBER SHEET OF
Certificate of Authorization	2	GENERAL REVISIONS	06/07/13	BT	DRAWN BY SWT	APPROVED BY AHL		MECHANICAL AND ELECTRICAL	115 130		
Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006.	0	742-2005 ADDENDUM 6 ISSUED FOR TENDER	06/05/29		SCALE:		RELEASED FOI CONSTRUCTIO R. SOROK	ON BY:	CONSULTANT DRAWING NO.	AUTOMATION / I AND C PLANT COMMUNICATION CABLE	CITY DRAWING NUMBER
То. 750 — Едриу. Ариг 50, 2000.	NC). REVISIONS	DATE	BY	DATE	2006/03/29	DATE 20	006/03/29	WH-A0615	TERMINATION DIAGRAMS	1-0601H-J-A0615-001-04B