





| REV. | CABLE TAG | CABLE SPECIFICATIONS | LENGTH (m) | FROM | TO | DESCRIPTION | REMARKS |
|------|----------------|------------------------------------|------------|---|--|---------------------------------|---------------------------|
| 2 | C-CP-H30A-C01 | 24-Strand 50/125/250 um Multi-mode | | CP-O30A Ozone Communication Panel | CP-H30A Plant Master PLC Communication Panel | Plant Communication | |
| 2 | C-CP-H30A-C02 | 24-Strand 50/125/250 um Multi-mode | | LCP-S11A Bulk Chemical Communication Panel | CP-H30A Plant Master PLC Communication Panel | Plant Communication | Not in Contract 742-2005. |
| 2 | C-CP-H30A-C03 | 24-Strand 50/125/250 um Multi-mode | | CP-O11A Liquid Oxygen Communication Panel | CP-H30A Plant Master PLC Communication Panel | Plant Communication | Not in Contract 742-2005. |
| 2 | C-CP-H31A-C01 | 24-Strand 50/125/250 um Multi-mode | | CP-P31A DAF Communication Panel | CP-H31A Primary Server Room Communication Panel | Plant Communication | |
| 2 | C-CP-H32A-C01 | 24-Strand 50/125/250 um Multi-mode | | CP-H30A Plant Master PLC Communication Panel | CP-H32A Backup Server Room Communication Panel | Plant Communication | |
| 2 | C-CP-O11A-C01 | 24-Strand 50/125/250 um Multi-mode | | CP-H30A Plant Master PLC Communication Panel | CP-O11A Liquid Oxygen Communication Panel | Plant Communication | Not in Contract 742-2005. |
| 2 | C-CP-O30A-C01 | 24-Strand 50/125/250 um Multi-mode | | LCP-R21A Residuals Communication Panel | CP-O30A Ozone Communication Panel | Plant Communication | |
| 2 | C-CP-P31A-C01 | 24-Strand 50/125/250 um Multi-mode | | CP-H32A Backup Server Room Communication Panel | CP-P31A DAF Communication Panel | Plant Communication | |
| 2 | C-JT-H951A-C01 | 2-Strand 50/125/250 um Multi-mode | | LCP-H10A Electrical Room No. 1 Communication Panel | JT-H951A | SWGR 1A Power Meter Comm. Cable | |
| 2 | C-JT-H951B-C01 | 2-Strand 50/125/250 um Multi-mode | | LCP-H10A Electrical Room No. 1 Communication Panel | JT-H951B | SWGR 1B Power Meter Comm. Cable | |
| 2 | C-JT-H952A-C01 | 2-Strand 50/125/250 um Multi-mode | | LCP-H10A Electrical Room No. 1 Communication Panel | JT-H952A | MCC 1A Power Meter Comm. Cable | |
| 2 | C-JT-H952B-C01 | 2-Strand 50/125/250 um Multi-mode | | LCP-H10A Electrical Room No. 1 Communication Panel | JT-H952B | MCC 1B Power Meter Comm. Cable | |
| 2 | C-JT-H953A-C01 | 2-Strand 50/125/250 um Multi-mode | | LCP-H10A Electrical Room No. 1 Communication Panel | JT-H953A | MCC 2A Power Meter Comm. Cable | |
| 2 | C-JT-H953B-C01 | 2-Strand 50/125/250 um Multi-mode | | LCP-H10A Electrical Room No. 1 Communication Panel | JT-H953B | MCC 2B Power Meter Comm. Cable | |
| 2 | C-JT-H954A-C01 | 2-Strand 50/125/250 um Multi-mode | | LCP-H10A Electrical Room No. 1 Communication Panel | JT-H954A | MCC 3A Power Meter Comm. Cable | |
| 2 | C-JT-H954B-C01 | 2-Strand 50/125/250 um Multi-mode | | LCP-H10A Electrical Room No. 1 Communication Panel | JT-H954B | MCC 3B Power Meter Comm. Cable | |
| 2 | C-JT-H961A-C01 | 2-Strand 50/125/250 um Multi-mode | | LCP-S11A Bulk Chemical Communication Panel | JT-H961A | SWGR 2A Power Meter Comm. Cable | Not in Contract 742-2005. |

| | | | | | | | | |
|--|-------------------|----------------------|---|-----------------|--|--|---|-----|
| NOTES:  Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006. | B.M. ELEV. | |    | | ENGINEER'S SEAL | | THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION | |
| | 5 | 498-2006 ADDENDUM 2 | 06/09/22 | BT | DESIGNED BY | SWT | | |
| | 4 | FOR CONSTRUCTION | 06/07/28 | BT | DRAWN BY | SWT | APPROVED BY | AHL |
| | 3 | GENERAL REVISIONS | 06/07/13 | BT | SCALE: NTS | | RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI | |
| | 2 | 742-2005 ADDENDUM 13 | 06/06/30 | BT | CONSULTANT DRAWING NO. WH-A0706 | | WATER TREATMENT PLANT PLANT UTILITIES MECHANICAL AND ELECTRICAL | |
| | 1 | 742-2005 ADDENDUM 6 | 06/05/25 | SWT | DATE 2006/03/29 | | AUTOMATION / I AND C PLANT COMMUNICATION CABLES CABLE LIST | |
| 0 | ISSUED FOR TENDER | 06/03/29 | SWT | DATE 2006/03/29 | | CITY FILE NUMBER SHEET 6 OF 10 CITY DRAWING NUMBER 1-0601H-K-A0706-001-05B | | |