



NOTES:

- ① BAS CONTROLLER #1.  
I/O POINTS WIRED TO GENERATOR DDC(BAS) CONTROL  
PANEL AS PER SPEC. SECTIONS 15900, 15901, 15902.  
TYPICAL FOR EACH OF 3 GENERATORS.



B.M. ELEV.					
DESIGNED BY	AB	CHECKED BY	AMA, PVL		
DRAWN BY	DJP	APPROVED BY	AHL		
SCALE:	AS NOTED	RELEASED FOR CONSTRUCTION BY:	R. SOROKOWSKI		
NO. REVISIONS	DATE	BY	DATE	2006/06/15	2006/08/30

ENGINEER'S SEAL	
ORIGINAL SIGNED BY	A. BURACHYNSKY
	2006/08/30
CONSULTANT DRAWING NO.	WG-H0502

**THE CITY OF WINNIPEG**  
WATER AND WASTE DEPARTMENT  
ENGINEERING DIVISION

**WATER TREATMENT PLANT**  
STANDBY POWER GENERATOR

CITY FILE NUMBER  
SHEET OF  
CITY DRAWING NUMBER  
1-06016-G-H0502-001-01D

MECHANICAL  
GN-E901A  
COOLING AND VENTILATION SCHEMATICS