


1 ROOF PLAN
1:100



- DRAWING NOTES**
- ① 915x1220 RELIEF AIR HOOD ON ROOF c/w MOTORIZED DAMPER. TERMINATE INTAKE OPENING APPROX. 600mm BELOW ROOF DECK. SEE DRAWING WG-H0402 DETAIL 5.
 - ② COMBINED VENTING/INLET AIR OPENING OF GAS FIRED UNIT HEATER.
 - ③ EXTEND REFRIGERANT SUCTION, LIQUID AND HOT GAS PIPING UP THROUGH ROOF TO CONDENSING UNITS. SEE WG-H401 DETAIL 6.

- GENERAL NOTES**
- 1. COORDINATE WITH OTHER TRADES SO AS TO PREVENT CONFLICTS.
 - 2. ALL DUCTWORK SHALL BE SUPPORTED AND SUSPENDED AS PER SPECIFICATIONS AND LOCAL CODES (SEE DETAILS).



B.M. ELEV.			 			ENGINEER'S SEAL		
						ORIGINAL SIGNED BY		
			DESIGNED BY	AB/LJW	CHECKED BY	AMA, PVL	A. BURACHYNSKY	
			DRAWN BY	LJW	APPROVED BY	AHL	2006/08/30	
			SCALE:	1:100	RELEASED FOR CONSTRUCTION BY:		CONSULTANT DRAWING NO.	
			NO. REVISIONS	DATE	BY	DATE	2006/05/29	2006/08/30
						R. SOROKOWSKI		WG-H0140

THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENGINEERING DIVISION

Winnipeg

WATER TREATMENT PLANT
 STANDBY POWER GENERATOR

MECHANICAL
 VENTILATION PLAN

CITY FILE NUMBER
 SHEET OF
 CITY DRAWING NUMBER
 1-0601G-A-H0140-001-020