



- DRAWING NOTES**
- REFER TO STRUCTURAL DRAWING 1-0601G-A-S0409-001-000 FOR CONCRETE DUCT BANK REQUIREMENTS.
 - 4160V SWITCHGEAR SUPPLIED BY CITY INSTALLED BY THIS CONTRACTOR.
 - ALL CONDUCTORS TO AND FROM SWGR-E100A SWGR-E100B SUPPLIED AND INSTALLED BY THIS CONTRACTOR.
 - DUCT BANK TO BULK CHEMICAL BUILDING SUPPLIED AND INSTALLED BY THIS CONTRACTOR TO CONTRACT LIMIT AS SHOWN ON DRAWING WG-E001.

APECM
 Certificate of Authorization
 Earth Tech Canada Inc.
 No. 730 Expiry: April 30, 2007

B.M. ELEV.			
DESIGNED BY	BLM	CHECKED BY	PS
DRAWN BY	ERC	APPROVED BY	AHL
SCALE:	NTS	RELEASED FOR CONSTRUCTION BY:	R. SOROKOWSKI
NO. REVISIONS	DATE	BY	DATE
02	498-2006 ADDENDUM 6	06/10/13	ERC
01	498-2006 ADDENDUM 4	06/10/10	ERC
00	ISSUED FOR TENDER	06/08/30	ERC
DATE	2005/10/03	DATE	2006/08/30

CH2M HILL
 Frederickson Cooper
 ARCHITECTS

EarthTech
 A Tech International Ltd. Company

ENGINEER'S SEAL
 ORIGINAL SIGNED BY
 B.L. MOORE
 2006/08/30

CONSULTANT DRAWING NO.
 WG-E0401

THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT
 ENGINEERING DIVISION

WATER TREATMENT PLANT
 STANDBY POWER GENERATOR

ELECTRICAL
 SINGLE LINE DIAGRAM
 MAIN DISTRIBUTION

CITY FILE NUMBER
 SHEET OF

CITY DRAWING NUMBER
 1-0601G-F-E0401-001-02D