LCP-T11A	Clearwell Communication Panel					
Rev.	Comments	Jumper or Internal Cable	Conductor #	Cable	Cable Information	
			PP1			
2	Plant Control Network Receive	Switch 1: 07	01	C-CP-J11A-C01B	24-Strand 50/125/250 um Multi-mode TO CP-H11A	
2	Plant Control Network Transmit	Switch 1: 07	02 02			
0	Remote I/O Network Receive	RIO Repeater 1: 01	03 03			
0	Remote I/O Network Transmit	RIO Repeater 1: 01	04			
2	Plant Monitoring Network Receive	Switch 2: 07	05 05			
2	Plant Monitoring Network Transmit	Switch 2: 07	06 06			
)	Spare		07 07			
)	Spare		08 08			
3	City of Winnipeg LAN		09 09			
3	City of Winnipeg LAN		10 10			
3	Fire Alarm		11 11			
<b>;</b>	Fire Alarm		12 12			
<b>;</b>	Security		13 13			
3	Security		14 14			
5	Remote I/O Network Receive	RIO Repeater 2: 01	15 15			
5	Remote I/O Network Transmit	RIO Repeater 2: 01	16 16			
2	Spare		17 17			
2	Spare		18 18			
2	Spare		19 19			
2	Spare		20 20			
2	Spare		21 21			
2	Spare		22 22			
2	Spare		23 23			
2	Spare		24 24			

NOTES:  1. Panel and Cabling are not in Contract 742-2005. Drawing Issued for Information Only. 2. Panel and Cabling are in Contract 498-2006.		B.M. ELEV.			CH2MHILL Frederickson Cooper ARCHITECTS		EarthTech A Tyco International Ltd. Company		ENGINEER'S SEAL  ORIGINAL SIGNED BY	THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION	
APEGIN	3 2	498-2006 ADDENDUM 6 498-2006 ADDENDUM 2 FOR CONSTRUCTION GENERAL REVISIONS	06/10/13 06/09/22 06/07/28 06/07/13	BT BT	DESIGNED BY DRAWN BY	SWT	CHECKED BY SWT APPROVED BY AHL	S.W. TORMEY 2006/03/29	WATER TREATMENT PLANT PLANT UTILITIES MECHANICAL AND ELECTRICAL	CITY FILE NUMBER  SHEET OF 130	
Certificate of Authorization  Earth Tech Canada Inc.  No. 730 Expiry: April 30, 2006.		742-2005 ADDENDUM 6 ISSUED FOR TENDER	06/05/29		SCALE:	NTS	RELEASED FOI CONSTRUCTIO R. SOROK	N BY:	CONSULTANT DRAWING NO.	PLANT COMMUNICATION CABLE	CITY DRAWING NUMBER
	NO.	REVISIONS	DATE	BY	DATE	2006/03/29	DATE 20	006/03/29	WH-A0619	TERMINATION DIAGRAMS	1-0601H-J-A0619-001-05B