


A SECTION
WS-H0110 1:50

- DRAWING NOTES**
- ① 300 GHS AND GHR TO BRIDGE.
 - ② 100 GHS AND GHR.
 - ③ 300 GHS AND GHR TO UNIT HEATER.
 - ④ 40 GHS SERVING EXPANSION TANK AND GLYCOL FILL TANK.
 - ⑤ 30 NATURAL GAS REGULATOR VENT FOR STEAM BOILER. SEE DRAWING WS-H0403 ROUND ROOF VENT DETAIL 3.
 - ⑥ 75 NATURAL GAS REGULATOR VENT FOR HYDRONIC BOILER. SEE DRAWING WS-H0403 ROUND ROOF VENT DETAIL 3.

GENERAL NOTES

1. COORDINATE WITH OTHER TRADES.



APEGM
Certificate of Authorization
Earth Tech Canada Inc.
No. 730 Expiry: April 30, 2007

B.M. ELEV.			
DESIGNED BY	JDB	CHECKED BY	PVL/AMA
DRAWN BY	DL	APPROVED BY	AHL
SCALE:	1:50	RELEASED FOR CONSTRUCTION BY:	R. SOROKOWSKI
NO.	01	DATE	2007/01/23
	00	DATE	2007/01/31
NO.	01	DATE	2007/01/31
REVISIONS		DATE	

CH2M HILL
Frederickson Cooper
ARCHITECTS

EarthTech
A Tyco International Ltd. Company

ENGINEER'S SEAL
ORIGINAL
SIGNED BY
A. M. AFTANAS
2007/01/31
CONSULTANT DRAWING NO.
WS-H0201

THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENGINEERING DIVISION

WATER TREATMENT PLANT
BULK CHEMICAL STORAGE
SODIUM HYPOCHLORITE AND CHEMICAL STORAGE BUILDING

MECHANICAL
SECTION A

CITY FILE NUMBER
SHEET OF
CITY DRAWING NUMBER
1-0601S-A-H0201-001-01D