




REV.	CABLE TAG	CABLE SPECIFICATIONS	LENGTH (m)	FROM	TO	DESCRIPTION	REMARKS
2	C-JT-H951A-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H951A	SWGR 1A Power Meter Comm. Cable	In Contract 742-2005.
2	C-JT-H951B-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H951B	SWGR 1B Power Meter Comm. Cable	In Contract 742-2005.
2	C-JT-H952A-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H952A	MCC 1A Power Meter Comm. Cable	In Contract 742-2005.
2	C-JT-H952B-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H952B	MCC 1B Power Meter Comm. Cable	In Contract 742-2005.
2	C-JT-H953A-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H953A	MCC 2A Power Meter Comm. Cable	In Contract 742-2005.
2	C-JT-H953B-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H953B	MCC 2B Power Meter Comm. Cable	In Contract 742-2005.
2	C-JT-H954A-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H954A	MCC 3A Power Meter Comm. Cable	In Contract 742-2005.
2	C-JT-H954B-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H954B	MCC 3B Power Meter Comm. Cable	In Contract 742-2005.
2	C-JT-H961A-C01	2-Strand 50/125/250 um Multi-mode		LCP-S11A Bulk Chemical Communication Panel	JT-H961A	SWGR 2A Power Meter Comm. Cable	In Contract 792-2006.
2	C-JT-H961B-C01	2-Strand 50/125/250 um Multi-mode		LCP-S11A Bulk Chemical Communication Panel	JT-H961B	SWGR 2B Power Meter Comm. Cable	In Contract 792-2006.
2	C-JT-H962A-C01	2-Strand 50/125/250 um Multi-mode		CP-H30A Plant Master PLC Communication Panel	JT-H962A	MCC 4A Power Meter Comm. Cable	In Contract 742-2005.
2	C-JT-H962B-C01	2-Strand 50/125/250 um Multi-mode		CP-H30A Plant Master PLC Communication Panel	JT-H962B	MCC 4B Power Meter Comm. Cable	In Contract 742-2005.
2	C-JY-H951A-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H951A	SWGR 1A Protection Relay Comm. Cable	In Contract 742-2005.
2	C-JY-H951B-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H951B	SWGR 1B Protection Relay Comm. Cable	In Contract 742-2005.
2	C-JY-H952A-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H952A	MCC 1A Protection Relay Comm. Cable	In Contract 742-2005.
2	C-JY-H952B-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H952B	MCC 1B Protection Relay Comm. Cable	In Contract 742-2005.
2	C-JY-H953A-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H953A	MCC 2A Protection Relay Comm. Cable	In Contract 742-2005.

NOTES:  <p>Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006.</p>	B.M. ELEV.				 		ENGINEER'S SEAL ORIGINAL SIGNED BY S.W. TORMEY 2006/03/29 CONSULTANT DRAWING NO. WH-A0706		THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION WATER TREATMENT PLANT PLANT UTILITIES MECHANICAL AND ELECTRICAL AUTOMATION / I AND C PLANT COMMUNICATION CABLES CABLE LIST		CITY FILE NUMBER	
	7	FOR CONSTRUCTION	06/12/01	BT							SHEET 6 OF 11	
	6	498-2006 ADDENDUM 6	06/10/13	BT	CITY DRAWING NUMBER							
	5	498-2006 ADDENDUM 2	06/09/22	BT	1-0601H-K-A0706-001-10B							
	4	FOR CONSTRUCTION	06/07/28	BT								
	3	GENERAL REVISIONS	06/07/13	BT								
	10	792-2006 ADDENDUM 5	06/04/11	BT								
	9	FOR TENDER (35-2006)	07/03/19	BT								
	8	ISSUED FOR TENDER	07/01/22	BT								
	NO.	REVISIONS	DATE	BY	DATE	2006/03/29					DATE	2006/03/29