



**NOTES**

1. SEE DRAWING WS-P0001 FOR CONTAINMENT PIPING AND CONTROLS.

**NH<sub>4</sub>OH BULK TANKS**

QTY: 2  
 CAPACITY: 37.5m<sup>3</sup> EACH  
 DIMENSIONS: 3.0m $\phi$  x 5.5m H  
 MATERIAL: 316L STAINLESS STEEL

 Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2007	B.M. ELEV.	 Frederickson Cooper ARCHITECTS	 A Tyco International Ltd. Company	ENGINEER'S SEAL	 THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION		
				DESIGNED BY: SBW		CHECKED BY: NT	ORIGINAL SIGNED BY: S.B. WILLIAMSON
				DRAWN BY: GLG		APPROVED BY: AHL	2007/01/31
				SCALE: NONE		RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI	CONSULTANT DRAWING NO. WS-P0012
	NO. REVISIONS	DATE	BY	DATE	WATER TREATMENT PLANT BULK CHEMICAL STORAGE SODIUM HYPOCHLORITE AND CHEMICAL STORAGE BUILDING PROCESS BULK AMMONIA OFFLOADING AND STORAGE PROCESS AND INSTRUMENTATION DIAGRAM		
					CITY FILE NUMBER SHEET OF CITY DRAWING NUMBER 1-0601S-G-P0012-001-030		