



# Bid Opportunity No. 278-2007 ADDENDUM No. 2

## TRANSIT DEPARTMENT PETROLEUM STORAGE AND HANDLING SYSTEMS REPLACEMENT.

### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY**

ISSUED: May 22, 2007  
BY: Lorne Stone  
TELEPHONE NO. (204) 956-0980

**THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS**

Template Version: A20070419

---

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

---

### **PART B – BIDDING PROCEDURES**

Revise B2.1 to read:

“The Submission Deadline is 12:00 noon Winnipeg time May 30, 2007.”

### **PART D – SUPPLEMENTAL CONDITIONS**

Add D2.2(b) (xi) “Supply and erection of new pumphouse.”

### **SPECIFICATIONS**

Revise drawing list in Part E – Specifications, clause E1.3 to read:

| <u>Drawing No.</u>     | <u>Drawing Name/Title</u>  |
|------------------------|--|
|                        | Cover Sheet  |
| 0729720100-DWG-B0001-0 | Osborne Street Garage Pump House Plan, Elevations, Sections and Details                        |
| 0729720100-DWG-S0001-1 | General Notes  |
| 0729720100-DWG-S0002-0 | Main Street Facility Concrete Slab Plans & Sections  |
| 0729720100-DWG-S0003-0 | Osborne Street Garage Concrete Slab Plans & Sections   |
| 0729720100-DWG-S0004-0 | Sections & Details   |
| 0729720100-DWG-S0005-0 | Osborne Street Garage Pump House Plans & Sections  |
| 0729720100-DWG-M0001-0 | Main Street Facility Mechanical – Flow Schematics  |
| 0729720100-DWG-M0002-0 | Main Street Facility Mechanical – Plan and Details   |
| 0729720100-DWG-M0003-0 | Osborne Street Garage Mechanical – Diesel Fuel and Waste Oil Flow Schematics                   |
| 0729720100-DWG-M0004-0 | Osborne Street Garage Mechanical – Plans and Details   |
| 0729720100-DWG-M0005-0 | Osborne Street Garage Mechanical – Miscellaneous Details                                       |
| 0729720100-DWG-E0001-0 | Typical Electrical Equipment Layout & Schematic Details at Osborne St. and Main St. Facilities |
| 0729720100-DWG-E0002-1 | Electrical Equipment Layout at Main Street Facility  |
| 0729720100-DWG-E0003-0 | Electrical Fuel Pump Control Schematic Diagrams  |
| 0729720100-DWG-E0004-1 | Electrical Fuel Pump Distribution Riser Diagrams and Panel Schedule                            |

Revise Section 02115, clause 2.5.1.2.2 to read.

“The waste oil storage tank in concrete vault is not to be removed but is to be abandoned in place. The tank is to be cleaned and purged of vapours, piping removed and tank filled with lean concrete or ECO Fill Grout as approved by Manitoba Conservation, to displace all air from tank. The size of the tank is approximately 9000 litres.”

Revise Section 13202, Clause 2.2.2.1 to read:

“Hand pump type pneumatic tank level gauge”

Revise Section 13202 Clause 2.2.2.2 to read:

”Acceptable material: Pneumercator Model P5”

## **DRAWINGS**

Replace drawing 0729720100-DWG-E0002, Rev 0 with drawing 0729720100-DWG- E0002, Rev.1.(Addendum No.2).

Replace drawing 0729720100-DWG-E0004, Rev 0 with drawing 0729720100-DWG-E0004, Rev.1. (Addendum No.2).