



## 458-2007 ADDENDUM 2

### ROOF REPLACEMENT AT THE FREIGHT HOUSE RECREATION CENTRE – 200 ISABEL

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: June 22, 2007  
BY: Norm Carrother  
TELEPHONE NO. (204) 794-4400

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20070419

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.**

---

#### **PART E – SPECIFICATIONS**

Revise: E4.4 to read:

Loose lay the custom cut type 2 expanded polystyrene insulation to fit between the ribs of the existing steel panels. The insulation is to be no thicker than the height of the highest rib in the panels. Loose lay the 1" type 2 expanded polystyrene overtop of the custom cut insulation.