

Exhaust Fan Schedule								
Tag	Service	Manufacturer	Model	Airflow (LPS)	TSP (Pa)	Motor (W)	Voltage	Accessories
F-1	Library Staff / WR / Track Jan	Greenheck	G-090-G	208	75	30	120 / 1	Factory roof curb
F-2	Lobby WR / Track WR	Greenheck	G-095-G	293	125	100	120 / 1	Factory roof curb
F-3	Network Room	Greenheck	CSP-A710	267	94	325	120 / 1	Vibration isolators
F-4	Roof Void	Greenheck	CSP-A2150	1,463	125	735	600 / 3	Vibration isolators
F-5	New Crawlspace	Greenheck	CSP-A700	300	188	350	120 / 1	Vibration isolators