



DWG M-3.1 PART PLAN

SCALE: 1: 150

GENERAL NOTES:

1. ALL INLET DUCTWORK ON FAN COIL UNITS SHALL BE INLET SIZED AND ACOUSTICALLY LINED. SUPPLY AIR DUCTWORK FROM FANCOIL UNIT SHALL BE ACOUSTICALLY LINED TO THE EXTENT SHOWN ON THE PLANS.

DRAWING NOTES:

- 19 GAS FIRED DOMESTIC HOT WATER HEATER, WITH SEPARATE FLUE GAS AND COMBUSTION AIR CONNECTIONS, INSTALLED ON 200mm (4") CONCRETE HOUSEKEEPING PAD. PROVIDE COMPLETE WITH THRU THE ROOF CONCENTRIC FLUE GAS/COMBUSTION AIR ADAPTER. SIZE AND INSTALL FLUE GAS AND COMBUSTION AIR PIPING ACCORDING TO THE REQUIREMENTS OF THE MANUFACTURER AND THE AUTHORITIES HAVING JURISDICTION. PIPE FLUE GAS CONDENSATE, IN ACCORDANCE WITH THE MANUFACTURERS INSTALLATION INSTRUCTIONS, TO THE NEAREST SUITABLY SIZED HUB DRAIN, PROVIDE CONDENSATE NEUTRALIZER, INSTALL IN ACCORDANCE WITH THE AUTHORITIES HAVING JURISDICTION.