



# ADDENDUM 5 BID OPPORTUNITY NO. 94-2007

## CITY OF WINNIPEG WATER TREATMENT PROGRAM CONSTRUCTION OF SITE UTILITIES

### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: June 14, 2007  
BY: Lawrence Recksiedler, C.E.T.  
TELEPHONE NO. (204) 986-4246

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20050301

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.**

---

### **PART A – BID SUBMISSION**

Replace 94-2007\_Addendum\_3-Bid\_Submission with 94-2007\_Addendum\_5-Bid\_Submission. Form G2(R3) has been replaced by Form G2(R4).

### **PART B – BIDDING PROCEDURES**

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, June 27, 2007.

### **PART D – SUPPLEMENTAL CONDITIONS**

Revise: D16.1(a) to read: November 16, 2007 – Completion of 750 Supernatent, 150 Sludge FM and Valve Chamber 1

Add: D16.1(b) December 14, 2007 – Completion of Valve Chamber 2

Revise: D24.1(n) to read: Construction of SUPERNATENT VALVE CHAMBERS 1 & 2 (construction of Valve Chamber 2 cannot start until September 17, 2007)

### **PART E – SPECIFICATIONS**

#### **Section 16015(R2)**

Revise: 2.2.7 to read: The Dewatering Pump Station is classified as a Category 1, Class 1, Zone 1 location. Construction methods and materials shall be suitable for the environment.

#### **Section 16121**

Revise: 2.1.8 to read: Interlocked aluminum armour

#### **Drawings**

Clarification: With respect to Drawing WL-E0111 rev. 4, Detail A/E0110, revise note to read: Category 1, Class 1, Zone 1 Location