



77-2008 ADDENDUM 1

FORT GARRY TWIN BRIDGES - WESTBOUND STRUCTURE REHABILITATION AND ASSOCIATED ROADWORKS

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: February 29, 2008
BY: Rick Haldane-Wilsone
TELEPHONE NO. (204) 956-0980

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, March 13, 2008.

PART D – SUPPLEMENTAL CONDITIONS

Revise: D15.6 to read The City intends to award this Contract by April 1, 2008.

PART E – SPECIFICATIONS

Revise: E13.1(b) to read This Specification shall cover the placement of MMFX 2 Grade 520 reinforcing steel and associated bar accessories. The Contractor shall be responsible for scheduling delivery in co-operation with the Contractor for the Fort Garry Twin Bridges – Supply and Delivery of Fabricated of MMFX 2 Reinforcing Steel, Bid opportunity 69-2008. For purposes of this Contract, MMFX 2 reinforcing steel shall be available for pickup in Winnipeg no later than June 13, 2008. All reinforcing steel shall be picked up no later than June 22, 2008. Safe and secure storage of MMFX 2 reinforcing steel is the responsibility of the Contractor after the date of availability.