



834-2008 ADDENDUM 2

WINNIPEG WATER TREATMENT PROGRAM – SUPPLY AND INSTALLATION OF TELEPHONE AND DATA SYSTEMS

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: March 25, 2009
BY: Bill Richert, P.Eng,
TELEPHONE NO. (204) 986-6053

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, March 30, 2009.

PART D – SUPPLEMENTAL CONDITIONS

Revise: D2.2 to read: The major components of the Work are as follows:

Revise: D2.3 to read: Wiring methods and Material used in the performance of the Work shall be consistent with the existing wiring methods, equipment and materials that the City has used in the immediate vicinity of the Work. This includes, but is not limited to, the supply and installation of multi-conductor Teck for cables run in tray outside of the WA-area of the WTP and the use of gel filled and rodent resistant Cat 3 multi-conductor cables in underground duct banks.