



## **ADDENDUM 2 BID OPPORTUNITY NO. 839-2008**

SUPPLY, DELIVERY, INSTALLATION, AND COMMISSIONING OF  
NATURAL GAS ENGINE DRIVE P26 AT THE MACLEAN PUMPING  
STATION

ISSUED: December 18, 2008  
BY: Claude Courchaine, P. Eng. –AECOM  
TELEPHONE NO. (204) 928-7415 or 284-0580

### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF BID  
OPPORTUNITY**

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.**

### **PART E – SPECIFICATIONS**

E1.3 Add the following specification sections to the existing list:

<u>Specification No.</u>	<u>Specification Title</u>
23 02 23	Pipe and Pipe Fittings
23 05 19	Meters and Gauges for HVAC Piping
23 05 23	Valves and Strainers

### **Additional Information**

The following NMS Specification Sections are attached:

23 02 23	Pipe and Pipe Fittings
23 05 19	Meters and Gauges for HVAC Piping
23 05 23	Valves and Strainers

### **Drawings**

Replace 1-0630M-M0004-001-Rev C. with revised drawing 1-0630M-M0004-001-Rev. D.

### **Clarification**

1. **Regarding Flexible Connectors:**

All flexible connections at the engine are referred to in Specification Section E9.18.2. They are to be specified by the engine Manufacturer, and shop drawings and information must be submitted by the Contractor for approval by the Contract Administrator.

**END OF ADDENDUM 2**