



822-2009 ADDENDUM No. 4

NORTH END AND SOUTH END WATER POLLUTION CONTROL CENTRE HAULED WASTEWATER RECEIVING FACILITIES AND ASSOCIATED WORKS

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: March 26, 2010
BY: Al Beghin, P. Eng.
TELEPHONE NO. (204) 489-5900

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, **April 1, 2010**.

PART E – SPECIFICATIONS

Revise: Section 40 20 01 Clause 2.1.7 to read: Fittings may be manufactured using standard schedule 40 SS butt weld fittings with two grooved schedule 40 SS stub pipe sections welded to each end of the fittings.

DRAWINGS

Revise: The drawing number 1-0101A-E0008-001 on 822-2009_Addendum_3_Drawing_1-0101A-E0008-0001-RA to read 1-0101A-E0009-001 on 822-2009_Addendum_4_Drawing_1-0101A-E0009-001-RA

Replace: 822-2009_Drawing_1-0101A-P0002-001-RA with 822-2009_Addendum_No. 4_Drawing 1-0101A-P0002-001-R1

822-2009_Drawing_1-0101A-P0003-001-RA with 822-2009_Addendum_No. 4_Drawing 1-0101A-P0003-001-R1

822-2009_Drawing 1-0101A-P0004-001-RA with 822-2009_Addendum_No_4_Drawing 1-0101A-P0004-001-R1

822-2009_Drawing 1-0101A-P0006-001-RA with 822-2009_Addendum_No_4_Drawing_1-0101A-P0006-001-R1

822-2009_Drawing 1-0101A-P0008-001-RA with 822-2009_Addendum_No_4_Drawing_1-0101A-P0008-001-R1

822-2009 Addendum_3_Drawing 1-0101A-E0008-001-RA with 822-2009_Addendum_No_4_Drawing_1-0101A-E0009-001-RA