



GENERAL NOTES 1

A. NEW OFFICES (FOUR TOTAL) TO BE CONTROLLED INDIVIDUALLY VIA OCCUPANCY SENSORS AS SHOWN; NOT WITH SWITCHING FOR THE OPEN AREA.

- DRAWING NOTES** ##
1. RELOCATED 2'X4' DIRECT/INDIRECT FIXTURE FROM TV ROOM AND RESOURCE LIBRARY. REFER TO DRAWING E0.2. CLEAN FIXTURE AND RE-LAMP. WIRE AND CONNECT TO EXISTING 347V LIGHTING CIRCUIT SERVING AREA WITH CAPACITY.
 2. RELOCATED OCCUPANCY SENSOR FROM TV ROOM/RESOURCE LIBRARY. REFER TO DRAWING E0.2. OCCUPANCY SENSOR TO CONTROL ALL LIGHTS IN ROOM; REWIRE RELOCATED LIGHT FIXTURES AS REQUIRED.
 3. NEW WALL MOUNTED OCCUPANCY TO MATCH EXISTING. OCCUPANCY SENSOR TO CONTROL ALL LIGHTS IN ROOM; REWIRE RELOCATED LIGHT FIXTURES AS REQUIRED.

1 PART MAIN FLOOR PLAN - LIGHTING
 E1.0R1 SCALE: 1:100

SMS ENGINEERING

SMS Engineering Ltd. Consulting Engineers
 770 Bradford Street Winnipeg MB Canada R3H 0N3
 Telephone 204.775.0291 Fax 204.772.2153
 sms@smseng.com

Project Title
RENOVATIONS TO ENGINEERING AND RECORD STORAGE AREAS - WATER AND WASTE OFFICES
 1199 PACIFIC AVE, WINNIPEG MB

Drawing Title
PART MAIN FLOOR PLAN LIGHTING
 1 REFERENCE TO GENERAL NOTE ADDED

Drawn By CM	Checked By CM	Approved By BDL
Scale 1:100	Date JANUARY 2010	Project No. 09-203-01
Revision Number 1	Drawing Number E1.0R1	Sheet Order 1 OF 1