



754-2010 ADDENDUM 2

**HVAC SYSTEM REPLACEMENT – NORTHWOOD COMMUNITY CENTER,
1415 BURROWS AVENUE**

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: November 2, 2010
BY: Coleen Groening
TELEPHONE NO. (204) 986-2491

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise Section 15800, Table 10, Model FWA93/DJ40/0 to now read: Model FWA285/DJS100/O.

Add

E3 CLARIFICATIONS

- E3.1 Community Centre will remove all existing stored goods within the compound.
- E3.2 Contractor shall replace any curbs that may be removed as part of the delivery of the unit.
- E3.3 Contractor to replace existing gas piping including existing PRV at exterior wall within compound. As required new piping is to be extended at 5 lbs pressure. Provide new individual regulators when reconnecting to existing equipment as well as new.
- E3.4 All new conduit feeds to equipment are to be fed overhead.