

914-2010 ADDENDUM 2

SUPPLY AND DELIVERY OF FIRE HOSES

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: November 30, 2010 BY: B Dupuis Smith TELEPHONE NO. (204) 986-2492

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E - SPECIFICATIONS

Revise: E2.2 to read: 1 ½ I.D. 150 PSI. PRESSURE TEST – BURST 500 PSI. 50 FT. COILS 10 INCH TO 12

INCH ROLL, UNCOUPLED WEIGHT OF COILED HOSE BETWEEN 6LBS. TO 8 LBS.

Revise: E2.3 to read: 2 ½ I.D. 150 PSI. PRESSURE TEST – BURST 500 PSI. 50 FT. COILS 12 INCH TO 15

INCH ROLL, UNCOUPLED WEIGHT OF COILED HOSE BETWEEN 12LBS. TO 14 LBS.

Revise: E2.4 (c) to read: Light weight compacted, flexible, -17C to 82C low temperature virtually non-kinking.

Revise: E2.4 (f) to read Couplings for the 1 ½ Heavy duty bronze or light weight aluminum alloy 2 rocker lug

expansion ring type rated for 200 PSI. Heavy duty thread NST male and female

complete with Buna Gasket.

Revise: E2.4 (g) to read: Couplings for 2 ½ I.D.: heavy duty bronze or light weight aluminum alloy for municipal

use. Expansion ring type rated for 200 PSI. Male and female attached hose thread ODM

3.25 IN. 6 TPI. 8.75 IN. 5 sided steamer ODM 4.84 IN.