



139-2012 ADDENDUM 1

BID OPPORTUNITY NO. 139-2012 – FRONT ENTRANCE UPGRADES AT ELMWOOD KILDONAN POOL – 909 CONCORDIA AVENUE

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: April 19, 2012
BY: Lou Chubenko
TELEPHONE NO. (204) 470-7881

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20120228

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, April 24, 2012.

PART D – SUPPLEMENTAL CONDITIONS

Add: D2.2(r) Patch and repair vertical face of concrete along exterior concrete plinth and provide new concrete parging finish to match new concrete finish on top.

PART E – SPECIFICATIONS

Revise: Section 08 71 00 as follows:

Add 3.6.3 Door D001 shall be equipped with a door contact or door status switch for an intrusion alarm and shall be integrated into frame/door.

Revise: Section 08 42 29 as follows:

Add 2.2.14 Door D002 shall be equipped with a door contact or door status switch for an intrusion alarm and shall be integrated into frame/door.